



Environment Protection Licence No.: 1694
Link to full licence on EPA website:
<http://www.epa.nsw.gov.au/prpoeoapp/>
Licensee: Edward River Council, PO Box 270 Deniliquin NSW 2710
Address of facility: Calimo Street, Deniliquin NSW

Monitoring Point 1

Location: Outlet from the Northern end of the Pond 4 into the drainage channel
Date data Published: 5th June 2025
NOTE: No discharged was recorded from Point 1 for the reporting month of June due to the operation of the effluent reuse scheme. No samples were taken for analysis.

Monitoring Point 3

Location: Flow meter downstream of Pond 4 outlet
Date data Published: 5th June 2025
Monitoring Period 1st May 2025 to 31st May 2025
NOTE: No flow was recorded at Point 3 for the reporting month of June due to the operation of the effluent reuse scheme.

Monitoring Point 4

Location: Effluent Reuse Pump Station adjacent Pond 4
Date data Published: 5th June 2025
Date data obtained: 22nd May 2025
Date Sampled: 7th May 2025

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	mg/l	Monthly	19
Chlorophyll-a	mg/m3	Monthly	88
Conductivity	uS/cm	Monthly	521
Escherichia coli	cfu/100ml	Monthly	200
Nitrogen (total)	mg/l	Monthly	18
Oil and Grease	mg/l	Monthly	2
pH	pH units	Monthly	8.1
Phosphorus (total)	mg/l	Monthly	4.71
Total Suspended Solids	mg/l	Monthly	15

Monitoring Point 5

Location: Flow meter downstream of Effluent Pump Station
Date data Published: 5th June 2025
Monitoring Period 1st May 2025 to 31st May 2025

Item	Unit	Monitoring frequency required by licence	Min. value	Max. value	Volume limit	Exceeds limit (yes/no)
Daily flow	kl/day	continuous	1212	3523	4000	No