



Environment Protection Licence No.: 1694
Link to full licence on EPA website:
<http://www.epa.nsw.gov.au/prpoeoapp/>
Licensee: Edward River Council, PO Box 270 Deniliquin NSW 2710
Address of facility: Calimo Street, Deniliquin NSW

Monitoring Point 1
Location: Outlet from the Northern end of the Pond 4 into the drainage channel
Date data Published: 9th of October 2023
NOTE: No discharged was recorded from Point 1 for the reporting month of **September** due to the operation of the effluent reuse scheme. No samples were taken for analysis.

Monitoring Point 3
Location: Flow meter downstream of Pond 4 outlet
Date data Published: 9th of October 2023
Monitoring Period 1st of September 2023 to 30th of September 2023
NOTE: No flow was recorded at Point 3 for the reporting month of **September** due to the operation of the effluent reuse scheme.

Monitoring Point 4
Location: Effluent Reuse Pump Station adjacent Pond 4
Date data Published: 9th of October 2023
Date data obtained: 23rd of September 2023
Date Sampled: 7th of September 2023

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	mg/l	Monthly	16
Chlorophyll-a	mg/m3	Monthly	5
Conductivity	uS/cm	Monthly	780
Escherichia coli	cfu/100ml	Monthly	5
Nitrogen (total)	mg/l	Monthly	23
Oil and Grease	mg/l	Monthly	3
pH	pH units	Monthly	7.4
Phosphorus (total)	mg/l	Monthly	3.24
Total Suspended Solids	mg/l	Monthly	8

Monitoring Point 5
Location: Flow meter downstream of Effluent Pump Station
Date data Published: 9th of October 2023
Monitoring Period 1st of September 2023 to 30th of September 2023

Item	Unit	Monitoring frequency required by licence	Min. value	Max. value	Volume limit	Exceeds limit (yes/no)
Daily flow	kl/day	continuous	738	1304	4000	No

.....end of report